

STRUCTURAL SOUNDNESS CERTIFICATE

STATEMENT ACCOMPANYING FORM - A

- 1) Door number of the building : Nil
- 2) Location : *Signature of the Panel Engineer*
 (Street number, Ward number, **KSR Mytikas Public School,**
 Name of place, i.e. Corporation / S.F.No.115/2, 115/3, 115/11,
 Municipality / Panchayat Union / Palur Village & Post,
 Township / Cantonment) Madhanur - 635804,
 Ambur Taluk,
 Tirupattur District.
- 3) Year of construction : GF - 2020, FF - 2021, SF - 2022,
- 4) Approximate cost of construction : Rs. 2,89,80,000/-
 as per current rates
- 5) Purpose for which the building is : CBSE school Purpose
 being used or proposed to be used
- 6) Purpose for which the building : CBSE school Purpose
 has hitherto been used
- 7) Details of construction of the building
 (Particulars of the foundations soil,
 Specification of various parts under)
- | a) Foundation | : | RCC column & footing | | | | | | | | | | | | | | | | |
|-----------------------------------|--------------|--|---------------|--------------|-------------|-------------|------------|--------------|----------|---------------|---|-------------|----------|---------------|---|--------------|----------|---------------|
| b) Basement | : | RCC column & plinth beam | | | | | | | | | | | | | | | | |
| c) Super structure | : | Brick walls in cement mortar | | | | | | | | | | | | | | | | |
| d) Floor and roof are to be given | : | <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;"></th> <th style="width: 20%; text-align: center;"><u>Floor</u></th> <th style="width: 20%; text-align: center;"><u>Roof</u></th> <th style="width: 30%; text-align: center;"><u>Area</u></th> </tr> </thead> <tbody> <tr> <td style="padding-left: 40px;">Main block</td> <td>Ground floor</td> <td>RCC roof</td> <td>19667.81 sqft</td> </tr> <tr> <td style="padding-left: 40px;">"</td> <td>First floor</td> <td>RCC roof</td> <td>18900.49 sqft</td> </tr> <tr> <td style="padding-left: 40px;">"</td> <td>Second floor</td> <td>RCC roof</td> <td>18900.49 sqft</td> </tr> </tbody> </table> | | <u>Floor</u> | <u>Roof</u> | <u>Area</u> | Main block | Ground floor | RCC roof | 19667.81 sqft | " | First floor | RCC roof | 18900.49 sqft | " | Second floor | RCC roof | 18900.49 sqft |
| | <u>Floor</u> | <u>Roof</u> | <u>Area</u> | | | | | | | | | | | | | | | |
| Main block | Ground floor | RCC roof | 19667.81 sqft | | | | | | | | | | | | | | | |
| " | First floor | RCC roof | 18900.49 sqft | | | | | | | | | | | | | | | |
| " | Second floor | RCC roof | 18900.49 sqft | | | | | | | | | | | | | | | |



8) Period for which licence is required : **01.08.2022 to 31.07.2025.**

9) No. of persons to be accommodated : **900 Students only.**
(Nine hundred students only)

Date : **01.08.2023**

Encl :- 1. Declaration (Page No.7)
2. Vellore Collector Panel order

**Proceedings of Vellore Dist.
Collector R. Dist. 22218/2017**

Signature of the Panel Engineer

Er. P.N.RAMESH BAABHU,
B.E,M.Tech,M.Sc(ReV),MIE,FIV,FIGV,C.Eng(I),MIITA,MICI
Chartered Engineer (M-119995-6/99)
Govt. Approved Valuer (F-1410)
Regd. Valuer for Wealth Tax (C-I/443-99)
Approved Valuer for Immoveable Properties (F-5636)
Regd. Engineer Class 1A (TN Public Buildings Act)
Panel Valuer for Banks, NBFI, IOCL, IFCI & HUDCO

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was granted for the use of the building or portion of building originally is changed or altered subsequently.

This is further to certify that no thatched buildings / inflammable roof buildings are used within this premises for the purpose noted in the statement. Any thatched building constructed / used after issue of this certificate, I would be held responsible for fire accident / mishap that may occur later and I am aware of that it is a punishable crime. Also other buildings of any types within this premises which were not opted / covered for the purpose which the licence was granted would be brought under the risk of my own.

The revenue details (Survey numbers, area & boundaries etc.,) and building details (Foundation, year of construction etc.,) mentioned in this certificate were provided by me only.

Date : **01.08.2023**

P. Lakshmi
Signature of the owner of the building

Date : **01.08.2023**

Signature of the Panel Engineer

**Proceedings of Vellore Dist.
Collector R. Dist. 22218/2017**

Er. P.N.RAMESH BAABHU,
B.E,M.Tech,M.Sc(ReV),MIE,FIV,FIGV,C.Eng(I),MIITA,MICI
Chartered Engineer (M-119995-6/99)
Govt. Approved Valuer (F-1410)
Regd. Valuer for Wealth Tax (C-I/443-99)
Approved Valuer for Immoveable Properties (F-5636)
Regd. Engineer Class 1A (TN Public Buildings Act)
Panel Valuer for Banks, NBFI, IOCL, IFCI & HUDCO

STATEMENT OF WORKS COMPANY
FORM - B

(Form of Certificate of Structural Soundness under sub-section(4) of section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965 (Tamil Nadu Act 13 of 1965) referred to in rule 4 of the Tamilnadu Public Buildings (Licensing) Rules 1966).

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

1) Foundation :

- | | | |
|---|---|-----------------------|
| i) Depth below ground level | : | 1.80 m |
| ii) Nature of soil met with at foundation level | : | Hard Gravel |
| iii) Pressure at foundation | : | 100 kN/m ² |
| iv) Probable safe bearing capacity of the strata met with at foundation | : | 300 kN/m ² |

2) Super structure :

- | | | | |
|--|---|-------------------------------------|-----------------------------------|
| i) Maximum stress in the most critical section of masonry and concrete | : | Masonry - 0.20 N/mm ² | Concrete - 5.00 N/mm ² |
| ii) Nature of Masonry & Concrete and its safe permissible stress | : | Brick work - 0.35 N/mm ² | Concrete - 9.00 N/mm ² |

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian Standard Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from **01.08.2022 to 31.07.2025.**

Date : 01.08.2023

Proceedings of Vellore Dist.
Collector R. Dist. 22218/2017

Signature of the Panel Engineer

Er. P.N.RAMESH BAABHU,
B.E.,M.Tech.,M.Sc(Rev),MIE,FIV,FIGV,C.Eng(I),MIITA,MICI
Chartered Engineer (M-119995-6/99)
Govt. Approved Valuer (F-1410)
Regd. Valuer for Wealth Tax (C-I/443-99)
Approved Valuer for Immovable Properties (F-5636)
Regd. Engineer Class 1A (TN Public Buildings Act)
Panel Valuer for Banks, NE FI, IOCL, IFCI & HUDCO
Mobile:94437 0200 1. 2. 3. 4. 5. 6. 7. 8. 9. 10. 11. 12. 13. 14. 15. 16. 17. 18. 19. 20. 21. 22. 23. 24. 25. 26. 27. 28. 29. 30. 31. 32. 33. 34. 35. 36. 37. 38. 39. 40. 41. 42. 43. 44. 45. 46. 47. 48. 49. 50. 51. 52. 53. 54. 55. 56. 57. 58. 59. 60. 61. 62. 63. 64. 65. 66. 67. 68. 69. 70. 71. 72. 73. 74. 75. 76. 77. 78. 79. 80. 81. 82. 83. 84. 85. 86. 87. 88. 89. 90. 91. 92. 93. 94. 95. 96. 97. 98. 99. 100.
ter @yahoo.com

STATEMENT TO ACCOMPANY**THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

1)	Location of the building (Door No, street name and name of the place)	KSR Mytikas Public School, S.F.No.115/2, 115/3, 115/11, Palur Village & Post, Madhanur - 635804, Ambur Taluk, Tirupattur District.
2)	Age of the building	GF - 3yrs, FF - 2yrs, SF - 1yrs,
3)	The Value of the building as per current rate	Rs. 2,89,80,000/-
4)	Number of Storeys	G + 2
5)	Short description of structures (Steel/RCC framed/Loadbearing)	RCC framed structure
6)	Purpose for which the building is certified for use	CBSE school Purpose
7)	The period for which the building will be structurally sound	01.08.2022 to 31.07.2025.
8)	No. of persons to be accommodated	900 Students only. (Nine hundred students only)
9)	Remarks	Nil

Date : 01.08.2023

Signature of the Panel Engineer

Proceedings of Vellore Dist.
Collector R. Dist. 22218/2017

Er. P.N.RAMESH BAABHU,
B.E.,M.Tech,M.Sc(ReV),MIE,FIV,FIGV,C.Eng(I),MIITA,MICI
Chartered Engineer (M-119995-6/99)
Govt. Approved Valuer (F-1410)
Regd. Valuer for Wealth Tax (C-I/443-99)
Approved Valuer for Immovable Properties (F-5636)
Regd. Engineer Class 1A (TN Public Buildings Act)
Panel Valuer for Banks, NBFI, IOCL, IFCI & HUDCO
TLR ASSOCIATES
Mobile:94434 42002

STATEMENT OF WORKS COMPANY
FORM - C

(Form of Opinion under sub-section (1) of section 5 of Tamilnadu Public Buildings (Licensing) Act 1965 (Chennai Act 13 of 1965) referred to in Rule 5 of the Tamilnadu Public Buildings (Licensing) Rules 1966).

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

1) Foundation :

- | | | |
|---|---|-----------------------|
| i) Depth below ground level | : | 1.80 m |
| ii) Nature of soil met with at foundation level | : | Hard Gravel |
| iii) Pressure at foundation | : | 100 kN/m ² |
| iv) Probable safe bearing capacity of the strata met with at foundation | : | 300 kN/m ² |

2) Super structure :

- | | | | |
|--|---|--------------|------------------------|
| i) Maximum stress in the most critical section of masonry and concrete | : | Masonry - | 0.20 N/mm ² |
| | : | Concrete - | 5.00 N/mm ² |
| ii) Nature of Masonry & Concrete and its safe permissible stress | : | Brick work - | 0.35 N/mm ² |
| | : | Concrete - | 9.00 N/mm ² |

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian Standard Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from

01.08.2022 to 31.07.2025.

Date : 01.08.2023

Signature of the Panel Engineer

**Proceedings of Vellore Dist.
Collector R. Dist. 22218/2017**

Er. P.N.RAMESH BAABHU,
B.E.,M.Tech,M.Sc(ReV),MIE,FIV,FIGV,C.Eng(I),MIITA,MICI
Chartered Engineer (M-119995-6/99)
Govt. Approved Valuer (F-1410)
Regd. Valuer for Wealth Tax (C-1/443-99)
Approved Valuer for immovable Properties (F-5636)
Regd. Engineer Class 1A (TN Public Buildings Act)
Panel Valuer for Banks, NBFI, IOCL, IFCI & HUDCO
T.R. ASSOCIATES

DECLARATION**STATEMENT TO ACCOMPANY****THE OPINION ON STRUCTURAL SOUNDNESS**

1)	Location of the building (Door No, street name and name of the place)	S.F.No.115/2, 115/3, 115/11, Palur Village & Post, Madhanur - 635804, Ambur Taluk, Tirupattur District.
2)	Age of the building	GF - 3yrs, FF - 2yrs, SF - 1yrs,
3)	The Value of the building as per current rate	Rs. 2,89,80,000/-
4)	Number of Storeys	G + 2
5)	Short description of structures (Steel/RCC framed/Loadbearing)	RCC framed structure
6)	Purpose for which the building is certified for use	CBSE school Purpose
7)	The period for which the building will be structurally sound	01.08.2022 to 31.07.2025.
8)	No. of persons to be accommodated	900 Students only. (Nine hundred students only)
9)	Remarks	Nil

Date : 01.08.2023

Signature of the Panel Engineer


**Proceedings of Vellore Dist.
Collector R. Dist. 22218/201.**

Er. P.N.RAMESH BAABHU,
B.E.,M.Tech.,M.Sc(ReV),MIE,FIV,FIGV,C.Eng(I),MIITA,MICI
Chartered Engineer (M-119995-6/99)
Govt. Approved Valuer (F-1410)
Regd. Valuer for Wealth Tax (C-I/443-99)
Approved Valuer for Immovable Properties (F-5636)
Regd. Engineer Class 1A (TN Public Buildings Act)
Panel Valuer for Banks, NBFI, IOCL, IFCI & HUDCO
TLR ASSOCIATES
Mobile: 94421 4200

DECLARATION

I, **Er. P.N. Ramesh Baabhu** son of Mr. P.M. Natarajan residing at D.No. 1A, TAMS Colony II cross, Old Railwayline road, Dharmapuri - 636701, Dharmapuri District do hereby declare that I possess the qualification and experience specified in the Table Rule 11 of the Tamil Nadu Public Buildings (Licensing) Rules 1966, for issuing the Certificate of Structural Soundness of the building covered by the certificate.

I am an **APPROVED & REGISTERED ENGINEER** with the **Collector of Vellore District** under Tamil Nadu Public Buildings (Licensing) Act 1965 & Rules 1966 to issue the Structural Soundness Certificate to public buildings.


Signature of the Panel Engineer

- | | | |
|------------------------------|---|--|
| 1) Name in Block letters | : | P.N. RAMESH BAABHU |
| 2) Engineering Qualification | : | BE, M.Tech, M.Sc(Val), MIE, FIV, CEng(I), MHITA, MICI, MASME. |
| 3) Experience | : | * 34 years as a Chartered Civil Engineer.
* Regd. Engineer Class-1A category by BOE.
* Panel Engineer with the Collector of Vellore District (Rc.No. A6/22218/2017) |

Disclaimer :

- 1) This certificate does not covers Legal aspects (Ownership, Survey numbers, boundaries & Area of the site) and issued without Prejudice.
- 2) This certificate does not covers and out-of-scope for any natural disasters like earthquake, cyclone, fire & anyother impacts which affects the stability of the buildings and also not covered the underground water sumps, septic tanks, borewells and open wells.
- 3) This certificate has been prepared based on the particulars provided by the client. If any informations in this certificate were found fault, this certificate will automatically gets cancelled.
- 4) Maintenance of the above buildings should be made periodically.
- 5) This certificate contains 7 pages and covers only the buildings mentioned therein and not any other buildings in the premises.
- 6) If the certificate is found tampered illegally, any corrections/ alterations, misuse for other purposes, without permission/ knowledge/ signature of the Panel Engineer, this certificate will automatically gets cancelled.

PROCEEDINGS OF THE VELLORE DISTRICT COLLECTOR
PRESENT: THIRU P.KUMARAVEL PANDIAN, I.A.S.,

Rc.No.A6/22218/2017

Dated:02.12.2021

Sub: Tamil Nadu Public Building (Licensing) Act 1965 -
Inclusion of the name of Er.P.N.Ramesh Babu in the
panel of Private Practicing Engineers under Class-IA
in Vellore District - Orders issued.

- Ref: (1) Thiru. P.N.Ramesh Babu, No.47A/2, 1st Floor,
DCK Complex, Bye Pass Road, Dharmapuri
application Dated:02.11.2017.
- (2) This office Lr.R.c.A6/22218/2017
dated:21.01.2021 addressed to the Engineer-in-
Chief, Chennai.
- (3) Engineer-in Chief, (Buildings) & Chief Engineer
(Buildings) Chennai Region, PWD, Chennai.
Lr.No.AEE/T10/003943/2020,Dated:20.10.2021.

<<<<>>>>

Order:

In ref. 1st cited Thiru.P.N.Ramesh Babu, residing at No.47 A/2, 1st Floor,
DCK Complex, Bye Pass Road, Dharmapuri had submitted requisition to include
his name in the panel of Private practicing Engineers under Class IA (One A) list
of Vellore Distr--ict.

2) In ref. 2nd cited read above, a proposal was sent to the Engineer-in-
Chief, Public Works Department (General), Chennai regarding recommending
inclusion of the individual's name in the list of panel of Private Engineers under
Class IA (One A) category.

3) In ref.3rd cited the Engineer-in-Chief (Buildings) & Chief Engineer
(Buildings Chennai region, PWD, Chepauk, Chennai has stated that the approved
the inclusion of the name of Thiru.P.N.Ramesh Babu, residing at No.47A/2, 1st
Floor, DCK Complex, Bye Pass Road, Dharmapuri to be included in the panel of
Private Practicing Engineers under Class IA (One A) category (Buildings, the cost
of which exceeds Rs.50.00 lakhs as per G.O.Ms.No.43, Municipal Administration
& Water Supply (MA4) Department, dated 17.2.2011) in Vellore District.



4) As per the recommendations of the Engineer-in Chief, WRD and Chief Engineer (General) PWD, Chepauk, Chennai in his letter third read above, the name of Thiru. P.N.Ramesh Babu is ordered to be included in the panel of Private Practicing Engineers under Class IA category (Buildings, the cost of which exceeds Rs.50.00 lakhs as per G.O.Ms.No.43, Municipal Administration & Water Supply (MA4) Department, dated 17.2.2011) in Vellore District.

5) All Revenue Divisional Officers and Tahsildars of Vellore District are instructed to accept the public building soundness certificate issued by Thiru. P.N.Ramesh Babu subject to conditions.

Sd/-P.Kumaravel Pandian
District Collector,
Vellore.

/By order/

[Signature]
For Collector,
Vellore.

To
✓ Thiru P.N.Ramesh Babu,
No.47A/, 1st Floor,
DCK Complex, Bye Pass Road,
Dharmapuri - 636 701.

[Signature]
02/11/2011

Copy to: RDO, Vellore, Gudiyatham,
Copy to: The Engineer-in Chief, WRD and Chief Engineer
(General) PWD, Chepauk, Chennai.



Date : 01.08.2023

Signature of inspecting authority or officer
appointed or having jurisdiction

FORM - E

(Form of report to be made to the competent authority by inspection authorities or officers appointed under other Acts under section 28 of the Tamilnadu Public Buildings (Licensing) Act 1965 (Tamil Nadu Act 13 of 1965) referred to in rule 7 of the Tamilnadu Public Buildings (Licensing) Rules 1966).

- 1) Name and Designation of inspecting authority or officer appointed or having jurisdiction under any other Act or Law. : **Er. P. N. Ramesh Baabhu,**
Collector Panel Engineer,
Vellore District.
- 2) Location of the building inspected : **KSR Mytikas Public School,**
(Door number, Street number, S.F.No.115/2, 115/3, 115/11,
Name of place, i.e. Corporation / Palur Village & Post,
Municipality / Panchayat Union / Ambur Taluk,
Township / Contonment) Tirupattur District.
- 3) Date of Inspection : 31.07.2023
- 4) Purpose for which the building is used : To run CBSE School
- | | | | | | |
|------------|---|--------------|---|----------|------|
| Main block | : | Ground floor | - | 19667.81 | sqft |
| „ | : | First floor | - | 18900.49 | sqft |
| „ | : | Second floor | - | 18900.49 | sqft |



- 5) Nature of Defects noticed : Nil
- 6) Suggestions for rectifying defects : --
- 7) If in a dangerous condition, immediate steps recommended to be taken : --
- 8) Period for which licence is required : **01.08.2022 to 31.07.2025.**

Date : 01.08.2023

***Signature of inspecting authority or officer
appointed or having jurisdiction***


Er. P.N.RAMESH BAABHU,
B.E.,M.Tech,M.Sc(ReV),MIE,FIV,FIGV,C.Eng(I),MIITA,MICI
Chartered Engineer (M-119995-6/99)
Govt. Approved Valuer (F-1410)
Regd. Valuer for Wealth Tax (C-1/443-99)
Approved Valuer for Immovable Properties (F-5636)
Regd. Engineer Class 1A (TN Public Buildings Act)
Panel Valuer for Banks, NBFI, IOCL, IFCI & HUDCO
TLR ASSOCIATES
Mobile:94434 42001 Email:tlrassociates@yahoo.com